



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail-soto-igp@police.ladakh.gov.in)

(Office Phone Number.01982-260888)

No: F&ES/Dir/NOC/2024- 15315-18

Dated: - 18 /09/2024

Subject: Fire NOC of Govt. High School Sangrah , Kargil.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the instant School building, wherein the spot visit has been conducted by I/c Fire and Emergency Services Station, Kargil. The detailed report of the School building is as under:

Location/ Accessibility:

The School building is constructed at Sangrah, Kargil. It is located at Latitude 34.22049492 and Longitude 76.97250885. The site is approximately 50 kms away from Fire and Emergency Services Station, Kargil. It takes approximately 01 hours and 30 minutes to reach the site and is approachable for fire appliances.

Detail of the building:

It is three storied building having single staircases. In the ground floor there are six class rooms. There are two windows in each room and the size is 7x6 feet. All the sides of the window have provision to open. **1st floor** have six class rooms and **2nd floor** has laboratory room, store room, table tennis room and hall.

There are 60 students and 16 staffs in the school.

The following Fire Safety equipment's are installed in the School building:

1. 02 number of fire extinguisher ABC type 06 Kg capacity is installed in the School building.
2. 02 number of sand bucket is appropriately placed in the school premises.
3. 01 number of plastic water tank 500 liters capacity is installed overhead of the school building.
4. 03 number of plastic water tank 1000 liters capacity and 500 liters capacity appropriately place in the school premises.

There is a mandatory requirement for keeping 1 exit staircases in each floor of the school building having 1.5 meter width besides constructing 20,000 liters capacity underground reserve water tank in the school premises along with the placement of 04 number of additional fire extinguishers ABC Type 6Kg capacity in the school building. The staff on duty should be given training of handling/operating fire safety equipment's, Luminous 'Fire Exit' sign should be provided at suitable location pointing towards exits for easy identification in case of emergency and the telephone numbers of Fire and Emergency Services, Station Kargil should be displayed at prominent places in the school premises.

Fire NOC is given in favor of **Govt. High School Sangrah, Kargil** for a period of **One Year** from the issuance of this letter and the school management is advised to fulfill the above listed fire safety requirements in the shortest possible time.

Director,
Fire and Emergency Services,
UT, Ladakh.

Copy to:

01. Headmaster, Govt. High School Sangrah, Kargil for information and n/a.
02. Superintendent of Police, F&ES Ladakh for information.
03. I/c F&ES Station Kargil for information.
04. Office File.